

BULLETIN

Date: 02/21/2020	Number: CT-04	Project #: 18157
Project Name: West Ridge SF		Attached:

Subject: Furring for 6 3/4" Header to WSW Strong Wall

Drawings Affected:

Description/Action:

This bulletin provides design clarifications for the balloon framing areas around stairs of all plans at the West ridge Single Family project located in Issaquah, Washington.

Furring for 6 3/4" Header to WSW Strong Wall shall be similar to detail 3/S6.3, but the fasteners need to be longer. Please use 1/4"x6" lag screws or Simpson SDS screws instead of 1 1/4" x 3 1/2" SDS or 16d.

3.5x LSL or 4x Doug fir are recommended to be used for blocking and shim.



02/21/2020

CALL WITH ANY QUESTIONS

Issued by:	Truc Thai	Date:	Feb 21, 2020
Distribution:			
Contact Information:			
	Jeremy Pfarr	Milbrandt Architects	
	Truc Thai	CT Engineering	